

Compliance Statement

No. 2021-300

Data communication cable, Category 5e

Company

INTELEK spol. s r.o.
Ericha Roučky 1291/4
627 00 Brno
Czech Republic

Product description

Screened cable (F/UTP) characterised up to 100 MHz
Horizontal floor wiring cable, 100 Ω
4 twisted pairs with overall foil screen
Flame retardant, halogen free

Product identification

Installation Cable Solarix CAT5E FTP LSOH Dca-s1,d2,a1 SXKD-5E-FTP-LSOH

Generic cabling and cabling components standards - Category 5e cable requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- IEC 61156-5:2020 (Ed. 3.0)
- EN 50173-1:2018 / EN 50173-2:2018
- EN 50288-2-1:2013
- TIA-568.2-D:2018

Standards for flammability, halogen acidity, and smoke performance

- IEC 60332-1-1:2015 (Ed. 1.1) / IEC 60332-1-2:2015 (Ed. 1.1)
- IEC 60754-2:2019 (Ed. 2.1)
- IEC 61034-1:2019 (Ed. 3.2) / IEC 61034-2:2019 (Ed. 3.2)

Technical report

12125977-01, DANAK-19/21892

EC Cabling product ID


7233

CS valid until

1 May 2022

This product has been tested by FORCE Technology and complies with the requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance schedule, which implies that FORCE Technology performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis.

Hørsholm, 20 April 2021


Lars Lindskov Pedersen
Test Manager


Dennis Andersen
Head of Department