

SOLARIXPEDIA

CPR: uwaga na niezgodności kabli B2ca i Cca

- Norma EN 13501-6 dzieli wyroby budowlane na tzw. **klasy reakcji na ogień**, w przypadku kabli komunikacyjnych są to klasy **Fca, Eca, Dca, Cca i B2ca**
- Poszczególne kable są zawsze oceniane dla tych klas (z wyjątkiem Fca) przez akredytowany, niezależny organ (znany jako **jednostką notyfikowaną**) zgodnie z dobrze zdefiniowanymi **procedurami i kryteriami**
- Zgodnie z Rozporządzeniem UE **305/2011** oraz normą **EN 50575** wszystkie kable **B2ca i Cca** muszą być testowane w trybie **AVCP 1+**, w przeciwnym razie nie będą spełniały wymagań prawnych i zostaną uznane **za NIEZGODNE**
- Produkty takie **nie mogą być wprowadzane do obrotu** przez producenta lub dystrybutora w żadnym państwie członkowskim UE
- Dlatego należy wymagać od dostawców kabli **B2ca i Cca**, aby posiadali **certyifikat AVCP 1+** (Certyifikat stałości właściwości użytkowych) z **dokładnym oznaczeniem** ocenianego wyrobu, który ma być zastosowany w instalacji
- Tylko kable poddane takim testom i **regularnym kontrolom** w trybie AVCP 1+ będą miały wymaganą odporność ogniową

	AVCP 1+	AVCP 3	AVCP 4
Wstępne badanie właściwości produktu	✓	✓	✗
Regularne testy kontrolne produktów	✓	✗	✗
Wstępna kontrola produkcji	✓	✗	✗
Regularne kontrole produkcji	✓	✗	✗
Odpowiadające sobie klasy reakcji na ogień	B2ca a Cca	Eca a Dca	Fca

PRZYKŁADOWY CERTYFIKAT AVCP 1+

Produkt: kabel instalacyjny Solarix SXKD-7A-1200-SSTP-LSOHFR-B2ca i SXKD-7-SSTP-LSOHFR-B2ca
Numer certyfikatu: 0200-CPR-03461
Jednostka notyfikowana: 0200 FORCE Certyfikacja



Certificate of constancy of performance

Regulation for Construction Products
Certificate No.: 0200-CPR-18569 version 01
Issued by FORCE Certification A/S - EC-notified body number 0200

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Power, control and communication cables

Product	Intended use	Class	AVCP system
Installation Cable Solarix CAT6A UTP LSOHFR B2ca-s1a,d1,a1 500m Part no.: 26000039 SXKD-6A-UTP-LSOHFR-B2ca	Supply of electricity and communication inside buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke	B2ca-s1a,d1,a1	1+

placed on the market under the name or trademark of:

INTELEK LTD
Dimophontos 1
Lamda Tower
1075 Nicosia
Cyprus, HE 438609

and produced in the manufacturing plant(s):

INTELEK LTD
Manufacturing plant 01

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the Annex ZZ of the standard:

EN 50575:2014 + A1:2016

under system 1+ for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 2024-12-11 and will remain valid until the specified expiry date as long as neither the harmonised standard, the construction product, the AVCP methods, nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by FORCE Certification A/S.

FORCE Certification A/S task No.: 124-34274. Certificate ID No.: 0200-CPR-18569-1.

Date of issue: 2024-12-11
Date of expiry: 2027-12-11

Dennis Andersen
Certification manager

Extracts from this Product Certificate may only be reproduced with a written permission from FORCE Certification A/S

NAJWAŻNIEJSZE ELEMENTY CERTYFIKATU AVCP 1+

Nazwa i numer certyfikatu, dane identyfikacyjne jednostki notyfikowanej

Certificate of constancy of performance

Regulation for Construction Products
Certificate No.: 0200-CPR-18569 version 01
Issued by FORCE Certification A/S - EC-notified body number 0200

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Power, control and communication cables

Product	Intended use	Class	AVCP system
Installation Cable Solarix CAT6A UTP LSOHFR B2ca-s1a,d1,a1 500m Part no.: 26000039 SXKD-6A-UTP-LSOHFR-B2ca	Supply of electricity and communication inside buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke	B2ca-s1a,d1,a1	1+

placed on the market under the name or trademark of:

INTELEK LTD
Dimophontos 1
Lamda Tower
1075 Nicosia
Cyprus, HE 438609

Opis i dokładne
oznaczenie
produktu

Producent

Klasa reakcji
na ogień badanego
kabla

System oceny
własności działania
AVCP 1+

Oznaczenie standardu określającego
wymagania systemu AVCP 1+, którego
spełnienie jest potwierdzone certyfikatem

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the Annex ZZ of the standard:

EN 50575:2014 + A1:2016

under system 1+ for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 2024-12-11 and will remain valid until the specified expiry date as long as neither the harmonised standard, the construction product, the AVCP methods, nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by FORCE Certification A/S.

FORCE Certification A/S task No.: 124-34274. Certificate ID No.: 0200-CPR-18569-1.

Date of issue: 2024-12-11
Date of expiry: 2027-12-11



Dennis Andersen
Certification manager

Data wydania i koniec
okresu ważności certyfikatu

www.solarix.eu